



TOWNSHIP OF MILLSTONE
Construction Department

County of Monmouth
Jeremy Kuipers, Construction Official

470 Stagecoach Road
Millstone Township, NJ 08510
Phone (732) 917-2953
Fax (609) 208-2083

**REMOVAL OF UNDERGROUND OIL TANKS
RESIDENTIAL**

- 1) Tank to be uncovered.
- 2) Top of tank to be removed, interior to be cleaned and free of all sludge.
- 3) Tank to be removed from excavation.
- 4) Inspection to observe the following;
 - A. Interior of tank cleaned.
 - B. Integrity of tank (holes in tank).
 - C. Bottom of excavation to be viewed for any evidence of petroleum products
- 5) Following documentation must be provided for closure of permit
 - A. Sludge dump ticket from licensed hauler.
 - B. Tank dump ticket from scrap metal dealer.
- 6) If tank has leaked or has any evidence of oil within excavation, DEP must be notified immediately with proper remediation to follow. Case # from DEP to be provided with ultimately a NFA letter when site is cleaned.